

DISTRICT :- SAMASTIPUR

Government of Bihar
Public Health Engineering Department

SUB DIVISION :- SAMASTIPUR

MONTH:- JUNE-2023

SLNO	BLOCK	PANCHAYAT	VILLAGE	LOCATION OF SOURCE	PARAMETERS									
					PH	EC	TDS	Fe	Alka	NO3	Turb	SO4	Remn	
1.	PAWA KALYANPUR	SAIDPUR	Sahuri	PUSA CENTRAL SCHOOL	7.2	415	270	0.2	140	BDL.	1	NT		
Desirable Limit					6.5-8.5	-	500 mg/l	1.0 mg/l	200 mg/l	45	1 NTU	200 mg/l		
Permissible * in Absence of Alternate source					NR	-	2000 mg/l	NR	200 mg/l	NR	5 NTU	400 mg/l		

Vinod Singh
51/06/23

SUB DIVISION CHEMIST
PUSA

Pratik Singh
5/6/23

SUB DIVISION PUSA